



NOTE:

OVERFLOW OUTLET TO BE RUN FULL SIZE (MINIMUM SIZE) TO CONDENSATE UNIT AVAILABLE OR AIR GAP/OPEN DRAIN.
 ALL PIPING MUST FOLLOW LOCAL, STATE AND FEDERAL CODES.

← DENOTES WHERE SHIPCO PIPING ENDS AND CONTRACTOR PIPING BEGINS →

SHIPPENSBURG PUMP CO., INC.			
TOLERANCES (EXCEPT AS NOTED)		SHIPCO®	
DECIMAL	ATMOSPHERIC OVERFLOW LOOP WITH ANTI-SYPHON / FILL PORT		
FRACTIONAL			
ANGULAR	MAT'L:	REV. 1	
	DRAWN BY: M.LINEAWEAVER	DATE: 01/16/08	ACAD FILE: K:\PIPING
SCALE: 1/16" = 1"	DRAWING NO: ATMOSPHERIC OVERFLOW LOOP		

SHIPCO®
 © 2008
 NOTE: THIS INFORMATION IS
 PROPRIETARY AND CONFIDENTIAL

B